

RC.NO.147/2024
DATED:


FIRE AND RESCUE STATION
NELLIKUPPAM

FIRE SAFETY CERTIFICATE

Certified that the **SRI VALLI VILAS ALAYA CBSE SCHOOL** at **vazhapattu post,panruti Taluk, cuddalore 607105** comprised of s.no 1/1,2,3,14/7A,14/7B,14/7C Ward C,Block no. 1&2, ground floor ,first floor and second floor owned by **SRI VALLI VILAS ALAYA CBSE SCHOOL**,(run by Sri Meenakshi shanmugam Educational trust) have complied with the fire prevention and safety requirements in accordance with rule of state fire service rules and verified by **M.KAVITHA station officer,fire and rescue station, nellikuppam** on **25.04.2024** in the presence of Thiru.SRINIVASAN chairman of the institution, cuddalore district and the building/premises is fit for occupancy class school premises with effect from **25.04.2024** for a period of one year in accordance with the rule and subject to compliance other conditions.

Conditions:

- 1.hose reel hose should be provided at every floor of building consisting ground floor+first floor and above with a fire pump capacity of 450 LPM
- 2.Old model fire extinguishers should be replaced by new type stored pressure fire extinguishers
3. 10000 lts of water tank should be provided separately for fire fighting purpose.



C.A. 25/4/24
STATION OFFICER
FIRE AND RESCUE STATION
NELLIKUPPAM

TO
THIRU.SRINIVASAN,
CHAIRMAN, SRI VALLI VILAS ALAYA CBSE SCHOOL
vazhapattu post,panruti Taluk, cuddalore 607105